



*Large duct penetrations have been made in the north wall of the South Portico Attic (402) without providing lintels to support the brick construction above. [JGWA, 2006]*